



CONCRETE ANCHOR PAD

DEADMEN ANCHORS

1. ANCHOR STRAPS MUST BE FLAT AND MADE OF GALVANIZED STEEL, CORROSION PROTECTED STEEL OR NON METALLIC MATERIALS SUCH AS FRP.
2. IF CABLE IS USED, THE CABLE MUST NOT CONTACT THE TANK'S PLASTEEL® FRP EXTERIOR. THE CABLE MUST BE SEPARATED FROM CONTACT WITH THE PLASTEEL® TANK FRP EXTERIOR BY USING A FLAT STEEL ANCHOR STRAP BETWEEN THE CABLE AND THE PLASTEEL TANK FRP LAMINATE.
3. CONSULT YOUR PLASTEEL TANK MANUFACTURER FOR THEIR SPECIFIC ANCHOR STRAP DESIGNS AND AVAILABILITY.
3. FLOAT OUT CALCULATIONS, DEADMEN ANCHOR DESIGNS AND CONCRETE SLAB ANCHOR DESIGNS ARE THE RESPONSIBILITY OF THE PLASTEEL® TANK OWNER OR THEIR ENGINEERING REPRESENTATIVE.

		2641 STATE STREET, SUITE #205		CARLSBAD, CA 92008	
		PHONE: 1-760-729-1083		FAX 1-760-729-1086	
SCALE: NONE	APPROVED BY:	DATE: 1-24-07		DRAWN BY:	
PLASTEEL® TANK					
TYPICAL TANK ANCHORING					