

MARK \subseteq ,Π ୍ଦ୍ର ŢΠ ٦ \triangleright UL COMPOSITE 2"X3" SECONDARY CONTAINMENT LABEL DIM 2; 2, FITTING SCHEDULE SCH 40 MONITOR ACCESS TUBE NPT SUBMERSIBLE TURBINE PUMP NPT FITTING W/ 2" TANK GAGE NPT AUTOMATIC OPTIONAL NPT FITTING NPT VENT NPT FILL DESRIPTION

Plasteel Composite® Double Wall Tank

8,000 GALLONS CAPACITY 30,400 LITERS

EMPTY WEIGHT ~ 10,300 LBS / 4,650 KILOGRAM


- TANK MUST BE UL LISTED AND LABELED COMPOSITE PER UL STANDARDS 58 AND 1746, PART II.
- TANK MUST BE INSTALLED PER THE PLASTEEL® TANK MANUFACTURER'S INSTALLATION INSTRUCTIONS.


 TANK MUST COMPLY WITH THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.

Ņ

N

- 4. WEIGHTS AND DIMENSIONS ARE APPROXIMATE. CONSULT WITH YOUR PLASTEEL TANK MANUFACTURER FOR SPECIFIC WEIGHTS AND DIMENSIONS.
- 5. THREADED CONNECTIONS ARE TYPICAL PIPING CONTAINMENT SUMP ATTACHMENT COLLARS ARE OPTIONAL CONSULT WITH YOUR PLASTEEL® TANK MANUFACTURER FOR DETAILS AND OPTIONS.
- TANK VENT FITTING SIZE MUST COMPLY WITH UI STANDARD 58.





PLASTEEL COMPOSITE® DOUBLE WALL TANK