

Northbrook, Illinois • (847) 272-8800 Melville, New York • (516) 271-6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549-1400 Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANC

CERTIFICATE NUMBER:

230197 - MH18314B

ISSUE DATE:

January 23, 1997

Issued to:

Plasteel Inc. 1189 Industrial Ave. Escondido, CA 92029

Report Reference:

MH18314, January 29, 1985

This is to Certify that representative samples of:

Type I or II Secondary Containment Composite Underground Tanks for Flammable Liquids

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL1746, External Corrosion Protection Systems for Steel Underground Storage Tanks; UL58, Steel Underground Tanks for Flammable and Combustible Liquids

Additional Information:

These are cylindrical horizontal tanks fabricated with a steel case and a combination of mechanical and hand lamination of chopped glass-fiber and polyester resin. The tanks are made in capacities of 500, 1000, 2000, 3000, 4000, 5000, 6000, 8000, 10,000, 12,000, 15,000, 20,000, 30,000, 40,000 and 50,000 U.S. gal. Tanks to be installed in accordance with the Mfr's instructions provided, the Flammable and Combustible Liquids Code, NFPA No.30

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - (1); the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer:

Underwriters Laboratories Inc. Dorothy Trawkowska

Review Engineer: