

Northbrook, Illinois • (847) 272-8800 Melville, New York • (516) 271-6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549-1400 Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIAN

CERTIFICATE NUMBER:

230197 - MH18314C

ISSUE DATE:

January 23, 1997

Issued to:

Plasteel Inc.

1189 Industrial Ave.

Escondido, CA 92029 U.S.A.

Report Reference:

MH18314, August 10, 1989

This is to Certify that

representative samples of:

Jacketed Underground Tanks for Flammable Liquids

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL1746, External Corrosion Protection Systems for Steel Underground Storage Tanks; UL58, Steel Underground Tanks for Flammable

and Combustible Liquids

Additional Information:

These are cylindrical horizontal tanks fabricated with an inner steel case, an interstitial material and a combination of mechanical and hand lamination of chopped glass-fiber and polyester resin for the outer jacket. The tanks are made in capacities of 500, 1000, 2000, 3000, 4000, 5000, 6000, 8000, 10,000, 12,000, 15,000, 20,000, 30,000, 40,000 and 50,000 U.S. gal. Tanks to be installed in accordance with the mfr's instructions provided,

the Flammable and Combustible Liquids Code, NFPA No. 30.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - 👊 ; the word " Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Underwriters Laboratories Inc. Dorothy Trawkowska

Review Engineer: